

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. C2/1100/24 Dated 27/02/24.

Dated: 27/02/24.

It is certified that an inspection team headed by C.J. Chacko, Technical Assistant Gr. I

(Name of Officers with designation) from Dist. Medical Office (Health) Kannur PHED

inspected the Sree Narayana Vidya Mandir Senior Secondary School

(Name & Address of the school) on 27/02/24.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. KWA/QA/R/02/444/J/72/45 dated 8/2/2024...

of KWA..... (PHED Lab) certified that the

S.N. Vidhyamandir..... (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6 months.....

Signature with Seal:

Name :

Designation :

Name & Address of the Office / Department :

To Principal
Sree Narayana Vidya Mandir Senior Secondary School
(Name & Address of the Institution)



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

ജില്ലാ മെഡിക്കൽ ഓഫീസ് (ആരോഗ്യം)
കണ്ണൂർ

PRINCIPAL
Sree Narayana Vidya Mandir
Senior Secondary School
TALAP, KANNUR-2

PRESIDENT
SREE NARAYANA VIDYA MANDIR
SENIOR SECONDARY SCHOOL
TALAP, KANNUR - 670002



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT

Tele phone No : 0497 2704380
email : kwaqclabkannur@gmail.com

Report No - KWA/QA/R/05/2051/J/35/536

Date : 09/05/2023

Customer Name and Address		1. Date of receipt		: 06-05-2023	
SN Vidyamandir Talap Kannur-2 (NON DOMESTIC PURPOSES)		2. Sampling Provided by		Customer (QUA_59568)	
		3. Sample Code		1794	
		4. Sample		Drinking Water	
		5. Source of Sample		Open Well	
		6. Sample quantity		: 100ml	
		7. Test performing dates			
		From: 08/05/2023		To: 09/05/2023	
Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500- 2012	Result
1	Total Coliforms	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	Nil
2	E.Coli	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	Nil

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

* End Of Report *

KWA/QC/KNR/R/17

Issue No: 02 Issue Date : 01.06.2021

Authorised By
[Signature]
Bacteriologist
QUALITY CONTROL DISTRICT LAB KANNUR
KERALA WATER AUTHORITY
Rev No: 001/06/2021

Page 1 of 1

[Signature]
6/2/24
PRINCIPAL
Sree Narayana Vidya Mandir
Senior Secondary School
TALAP, KANNUR-2

[Signature]
PRESIDENT
SREE NARAYANA VIDYA MANDIR
SENIOR SECONDARY SCHOOL
TALAP, KANNUR - 670002



**KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT**



TC-9558

Tele phone No : 0497 2704380

email : kwaqclabkannur@gmail.com

ULR-TC9558230000002051F

Report No - KWA/QA/R/05/2051/1/07/1938			Date : 09/05/2023		
Customer Name and Address			1. Date of receipt		: 06-05-2023
SN Vidyamandir Talap Kannur-2 (NON DOMESTIC PURPOSES)			2. Sampling Provided by		Customer (QUA_59568)
			3. Sample Code		1794
			4.. Sample		Drinking Water
			5. Source of Sample		Open Well
			6. Sample quantity		: 1 lit
			7. Test performing dates		
					From : 06/05/2023

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Taste		IS 3025 (Part 8)-1984 (Reaffirmed 2017)	Agreeable	-
2	Colour	HAZEN	IS 3025 (part 04) -2021	5	-
3	Odour		IS 3025 (part 5) -2018	Agreeable	-
4	Turbidity	(NTU)	IS 3025 (part 10) -1984 (Reaffirmed 2017)	1	0.06
5	pH		IS 3025 (part 11) - 2022	6.5 to 8.5	5.17
6	Total Alkalinity (as CaCO ₃)	(mg/litre)	IS 3025 (part 23) -1986 (Reaffirmed 2019)	200	-
7	Total Dissolved Solids (TDS)	(mg/litre)	IS 3025 (part 16) -2023 Second Revision	500	-
8	Total Hardness (as CaCO ₃)	(mg/litre)	IS 3025 (part 21) -2009 (Reaffirmed 2019)	200	25.22
9	Calcium (as Ca)	(mg/litre)	IS 3025 (part 40) -1991 (Reaffirmed 2019)	75	-
10	Magnesium (as Mg)	(mg/litre)	IS 3025 (part 46) -1994 (Reaffirmed 2019)	30	-
11	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) -1988 (Reaffirmed 2019)	250	22.68

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

*BDL - Below Detection Limit

Authorised By

Rekha V K

Sr. Sanitary Chemist

SR. SANITARY CHEMIST

QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY

Rev Date: 01.06.2021
Rev No: 001

Page 1 of 1

KWA/QC/KNR/R/17

* End Of Report *

Issue No: 02

Issue Date: 01.06.2021

PRINCIPAL
Sree Narayana Vidya Mandir
Senior Secondary School
TALAP, KANNUR-2

PRESIDENT
SREE NARAYANA VIDYA MANDIR
SENIOR SECONDARY SCHOOL
TALAP, KANNUR - 670002



**KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT**

Tele phone No : 0497 2704380
email : kwaqclabkannur@gmail.com

Report No - KWA/QA/R/05/2051/J/07/1938

Date : 09/05/2023

Customer Name and Address

SN Vidyamandir

Talap

Kannur-2

(NON DOMESTIC PURPOSES)

1. Date of receipt

: 06-05-2023

2. Sampling Provided by

Customer (QUA_59568)

3. Sample Code

1794

4. Sample

Drinking Water

5. Source of Sample

Open Well

6. Sample quantity

: 1 lit

7. Test performing dates

From : 06/05/2023

To : 06/05/2023

Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14) -2013 (Reaffirmed 2019)		131.00
2	Acidity	(mg/litre)	IS 3025 (part 22) -1986 (Reaffirmed 2019)		-
3	Sulphate (as SO ₄)	(mg/litre)	IS 3025 (part 24) -1986 (Reaffirmed 2019)	200	-
4	Fluoride (as F)	(mg/litre)	APHA23rd Edition 4500-F-D. SPADNS Method	1	-
5	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) -2003 (Reaffirmed 2014)	1	BDL
6	Nitrate (as NO ₃)	(mg/litre)	APHA23rd Edition 4500 NO ₃ -B(UV Screening Method)	45	18.56
7	Ammonia (as NH ₃ -N)	(mg/litre)	IS 3025 (Part 34)-1988 (Reaffirmed 2019)	0.5	-
8	Phosphorous (as P)	(mg/litre)	IS 3025 (part 31/sec 1): 2022		-
9	Dissolved Oxygen	(mg/litre)	IS 3025(Part 38)-2009(Reaffirmed 2019)		-
10	Total Suspended Solids	(mg/litre)	IS 3025(Part17)-Second revision 2012		-
11	Oil and Grease	(mg/litre)	IS 3025 (Part 39)- 2021		-
12	Bio chemical Oxygen Demand	(mg/litre)	IS 3025(Part 44)-1993(Reaffirmed 2019)		-
13	Chemical Oxygen Demand	(mg/litre)	IS 3025 (Part 58)-2006(Reaffirmed 2017)		-
14	Residual Chlorine	(mg/litre)	IS 3025 (part 26) -1986 (Reaffirmed 2019)	0.2	-

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

*BDL - Below Detection Limit

PRINCIPAL
Sree Narayana Vidya Mandir
Senior Secondary School
TALAP, KANNUR-2

PRESIDENT
SREE NARAYANA VIDYA MANDIR
SENIOR SECONDARY SCHOOL
TALAP, KANNUR - 670002

Authorised By
SR. SANTHA V. CHEMIST
QUALITY CONTROL Chemist
KERALA WATER AUTHORITY
KANNUR
Rev No: 001
01.06.2021